

WaterSense® Labeled New Home Inspection Checklist

Site Information							
Builder Name:							
Lot Number/Street Address/Unit Number:							
City, State, Zip:							
Inspection Information							
Inspection Company:							
Inspector Name:							
Date:							
Time Started:				Time Completed:			
Sampling Protocol Information						Yes	No
Is this home being sampled and inspected as part of a sampling protocol for multiple homes in a planned community, subdivision, or multi-family building?							
Were the first seven homes in this planned community, subdivision, or multi-family building all directly inspected and certified?							
Was this home randomly selected for sampling from a group of seven homes that are scheduled for completion within 30 days of one another? (Provide additional information as indicated below for the homes covered by this sampling protocol.)							
Building Information						Yes	No
Is the home being inspected as a unit within a multi-family building?							
If yes, are all applicable building requirements met? (Provide responses to the requirements listed below.)							
Item	Section	Prerequisite Multi-Family Building Criteria	Yes	No	NI [*]	Doc [†]	
Metering	3.9	Water metering/tracking for each unit					
Common use clothes washers	3.7.2	ENERGY STAR® qualified				Req.	
		Water factor ≤ 6.0				Req.	
Notes on Multi-Family Building Criteria							
By affixing my signature below, I do hereby declare that I have inspected the home in accordance with the <i>WaterSense New Home Specification</i> and the <i>Inspection and Verification Guidance for WaterSense Labeled New Homes</i> and will provide, if requested, the necessary supporting documents.							
Inspector Name:				Company:			
Signature:				Date:			

^{*} Not installed (NI)

[†] Documentation required (Req.) to be provided by the builder

Item	Section	Home or Unit Criteria	Yes	No	NI*	Doc†
Indoor Water Efficiency Criteria						
Leaks	3.1	Pressure-loss test on all water supplies detected no leaks				
		No visible leaks from hot water delivery system				
		No visible leaks from toilets/urinals				
		No visible leaks from bathroom faucets				
		No visible leaks from kitchen faucets				
		No visible leaks from showerheads				
Service pressure	3.2	No visible leaks from other fixtures or appliances				
		Single-family: Pressure tank installed and set ≤ 60 psi OR				
		Single-family: PRV installed upstream of fixtures and pressure test ≤ 60 psi OR				
		Single-family: Pressure test ≤ 60 psi and written documentation from water supplier that pressure ≤ 60 psi				Req.
Hot water delivery	3.3	Multi-family: Pressure test ≤ 60 psi				
		Acceptable system type				
Toilets	3.4.1	10°F temp. change within ≤ 0.6 gallons				
Flushing urinals	3.4.2	WaterSense labeled				Req.
Bathroom sink faucets	3.5.1	WaterSense labeled				Req.
		Measured flow rate—maximum 1.5 gpm (Flow test maximum: 0.25 gallons)				
Kitchen sink faucets	3.5.2	Measured flow rate—maximum 2.2 gpm (Flow test maximum: 0.4 gallons)				
Showerheads	3.6	WaterSense labeled				Req.
		Measured flow rate—maximum 2.0 gpm water per shower compartment ≤ 2,160 in ² (Flow test maximum: 0.35 gallons/compartment)				
		Separate controls for showerheads if > 2160 in ²				
Dishwashers	3.7.1	ENERGY STAR qualified				Req.
Clothes washers	3.7.2	ENERGY STAR qualified				Req.
		Water factor ≤ 6.0				Req.
Evaporative cooling system	3.8.1	Acceptable system type				Req.
		Maximum 3.5 gal/water/ton hour cooling, maximum 3 blowdowns in 24 hours				Req.
		Controls blowdown through conductivity or a basin temperature-based controller				Req.
Water softeners	3.8.2	Certified to NSF/ANSI Standard 44, including voluntary efficiency rating standards in Section 7				Req.
Drinking water	3.8.3					Req.

* Not installed (NI)

† Documentation required (Req.) to be provided by the builder

treatment systems		NSF/ANSI certified, minimum efficiency rating 85%				
Notes on Indoor Water Efficiency Criteria						

Item	Section	Home or Unit Criteria	Yes	No	NI*	Doc†
Outdoor Water Efficiency Criteria						
Landscape design	4.1	Single-family: Front yard landscaped				
		All improved upon areas landscaped				
		Temporary landscape installed				
	4.1.1	Landscapable area of lot ≤ 1,000 ft ² and exempt from landscape design criteria				
	4.1.1.1	Water budget tool calculations verified				Req.
		Landscape complies with water budget design				Req.
Slopes	4.1.2	Slopes ≥ 4:1 are vegetated				
Mulching	4.1.3	No exposed soil				
		All mulch is 2 to 3 inches deep				
Pools/spas	4.1.4	Single-family: Cover installed				
		Multi-family: Independently metered				
		Multi-family: Gutter or grate system				
		Multi-family: Sorptive media or cartridge filtration system				
Ornamental water feature	4.1.5	Recirculates water and serves beneficial use				
Irrigation system	4.2	WaterSense labeled weather-based irrigation controllers or approved soil moisture sensor-based controller				Req.
		Multi-family: Independently metered				
		Designed or installed by an irrigation professional certified by a WaterSense labeled program				Req.
		Provided waiver for design/installation				Req.
		System audited by certified irrigation professional				Req.
		<i>Irrigation System Audit Checklist</i> completed by certified irrigation professional				Req.
		Provided waiver for audit				Req.
Notes on Outdoor Water Efficiency Criteria						

* Not installed (NI)

† Documentation required (Req.) to be provided by the builder

Item	Section	Home or Unit Criteria	Yes	No	NI*	Doc†
Homeowner or Resident and Building Management Education Criteria						
Single-family/ occupant operating manual	5.2	Written operating and maintenance manual (or chapter) for all water-using equipment/controls installed in house, unit, yard, or common use outdoor area				
		General information on water-efficient dishwashers and clothes washers if they are not installed				
Building operating manual	5.3	Multi-family: Manual for all water-using equipment and controls outside of individual dwellings or inside of individual dwellings that are maintained by building management				
Irrigation system	5.2	Schematic, itemized list of irrigation components, copies of irrigation schedules, and information on reprogramming schedules included in operating manual for homeowners of single-family homes and for building managers for multi-family buildings				
Pools/spas	4.1.4	Multi-family: Detailed information on filtration equipment and manufacturer's recommended maintenance schedule to building management				
Notes on Homeowner Education Criteria						

* Not installed (NI)

† Documentation required (Req.) to be provided by the builder